


APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.No. DLWTL-13-02H41Date : 13/11/2020

It is certified that an inspection team headed by YUGAL PRASAD SINGH (Name of Officers with designation) from D.W.S.D, HAZARIBAG (Name of Department/Office) inspected the MUNAM SCHOOL, BENDI, KATKAMDAG, HAZARIBAG (Name & Address of the School) on 13/11/2020 and found that the MUNAM SCHOOL, BENDI, KATKAMDAG, HAZARIBAG (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 year.Signature with Seal : 

Name

: YUGAL PRASAD SINGH

Designation

: Assistant Engineer
अवर प्रपंडल ऑफिस हजाराबाग


To

MUNAM SCHOOL,
BENDI, KATKAMDAG,
HAZARIBAG

(Name & Address of the Institution)

Md. Akhmed.
PRINCIPAL
MUNAM SCHOOL
BENDI, KATKAMDAG
HAZARIBAG

86


MANAGER
MUNAM SCHOOL
BENDI, KATKAMDAG
HAZARIBAG

District Level Water Testing Laboratory
Hazaribagh, Jharkhand

Drinking Water and Sanitation Division, Hazaribagh

Panchayat:- Adra
Village:- Bendi

Location:- Jharkhand, District:-Hazaribagh

Sample Name:- Katkamdag
Sample collected on date: 13/11/2020
Sample analysed on date: 13/11/2020

Sl. No.	Village / Location	Sample No.	Taste	Turbidity (NTU)	Ph Value	Alkalinity (Mg/l)	Chloride (Mg/l)	Iron (Mg/l)	Hardness	Fluoride (Mg/l)	TDS	Nitrate	Remarks
1	BIS STANDARD LIMIT	3	4	5	6	7	8	9	10	11	12	13	14
2	MUNAM SCHOOL, BENDI, KATKAMDAG, HAZARIBAG.	HAZ03	Agree	0.2	7.99	32.3	20	0.21	361	0.18	196.3	-	potable

Md. Anand
PRINCIPAL
MUNAM SCHOOL
BENDI, KATKAMDAG
HAZARIBAG

Dr. Anurag Singh
MANAGER
MUNAM SCHOOL
BENDI, KATKAMDAG
HAZARIBAG

Signature
13/11/2020
Assistant Engineer,
D.W. & S. Sub. Division No.-1, Hazaribagh
अवर प्रभार इंजीनियर

Asst. Technical Manager
District Level Water Testing Laboratory
Hazaribagh